

## Effect of Mean Temperature on K-Flex Insulation K-Factors

The k-factor of elastomeric closed cell foams decreases (improves) as the mean temperature decreases in a linear fashion. It should be pointed out that k-factors are always reported for mean temperatures. The testing apparatus used to determine thermal conductivity “sandwiches” the test sample between two plates. The plates are set at different temperatures: one plate is designated as the hot side with the other plate designated as the cold side. The mean temperature is determined by adding the surface temperatures of both plates and dividing by two. When comparing the insulation value of different types of insulation, it is important to look at the k-factor AND the mean temperature.

The k-factor for K-Flex Insul-Tube and Insul-Sheet has been determined at the following mean temperatures:

### Elastomeric Insulation

<u>Mean Temperature</u>	<u>k-factor</u>
90°F	0.27
75°F	0.245
-40°F	0.23
-125°F	0.19
-165°F	0.18
-256°F	0.14
-297°F	0.13

Listed below are the boiling points of several cryogenic substances:

Butane	31.1°F	Oxygen	-297°F
Chlorine	-29.4° F	Propane	-43.8°F
Ethane	-127.5°F	Radon	-79.1°F
Isobuate	11.0°F	Xenon	-162.5°F
Liquid Nitrogen	-320.3°F	LNG	-259°F

Caution: Design and installation of any system operating at temperatures below the boiling point of oxygen or other potentially explosive substances should only be performed by highly trained and certified professionals.