

UL THIRD PARTY SUPERVISION AND LISTED K-FLEX PRODUCTS

K-Flex USA Insul-Tube and Insul-Sheet elastomeric insulation products have been tested in accordance with test methods under the jurisdiction of UL for flammability characteristics per UL94 (HBF, VO, 5V). These products are UL recognized under K-Flex USA, file #E300774, (UL Web Site – www.UL.com). K-Flex® elastomeric tape products are also listed as meeting UL94 5V when tested adhered to a metal plate.

K-Flex Insul-Tube and Insul-Sheet, F-Fit Fittings made from Insul-Tube or sheet, K-Flex Clad WT and K-Flex Duct Liner Gray are all UL Environment Greenguard Gold Certified as low VOC products. These products are also UL Validated for Mold Resistance based on UL 2824 / ASTM D 6329 test performance.

Other material properties have been confirmed by other certified, nationally recognized, independent laboratories. While independent labs are able to guarantee that tested materials comply with the UL test standards and requirements, they do not have the authority to issue UL certification. UL 181 and UL 723 would be examples tests conducted to UL standards by other independent testing laboratories.

A UL listing / approval / validation / certification program typically involves periodic follow up to the manufacturing location for continual testing and monitoring of the listed / approved / certified product(s). This program serves to verify and assure that product quality and performance properties, along with the manufacturing practices, remain consistent.

Factory Mutual Research Corporation (FMRC)

K-Flex USA Insul-Tube brand extruded tubular insulation products are approved and listed by Factory Mutual Research Corporation. Refer to Technical Bulletin TS08 for additional information.

